

DUO Broadband Pole Attachment Standards

Unless otherwise specified below, all attachments must comply with Attachment Specifications in the Company's tariff that governs pole attachments.

Minimum Clearance:

- Driveways / Parking lots – Clearance is 16'
- County roads – Clearance is 18'
- State roads – Clearance is 18'
- Railroads – Clearance is 27'
- Interstates – Clearance is 24'
- Spaces and ways subject to pedestrians or restricted traffic only – Clearance exception is 16'
- Standard separation between attachment points is 12 in between communications plant.

Any additional positions on a pole must be made above DUO Broadband facilities.

Attachment positions must be no less than 12" from the top of the pole.

The J7908 or Becky Reinforcement Strap using a hammer driven lag bolt must be used for Company facilities rearranged by the Attacher.

Anchors must be in place before strand is tightened/sagged. Strand must be tightened/sagged from anchor to anchor and sagged to be uniform with existing facilities so not to cross or overlap mid span.

Attacher must provide and use their own anchor and guy and cannot attach or use DUO Broadband anchor and guy.

Grounding and bonding to the strand and pole ground is required

Attachments must be tagged with owner identification at each pole.